

Core Wrapping	A closed helical or longitudinal lapping of non-hygroscopic, non-wicking polyester tape or tape of another suitable material		
Moisture Barrier/Screen	An Aluminium tape of nominal $0.2 \pm 10\%$ thickness with PE coated on both sides having thickness 0.05mm nominal on each side shall be longitudinally applied with an overlap of min. 3 mm or 6 mm as applicable		
Sheath	Extruded polyethylene of grade 03C or H03C as per BS 6234. Thickness & diameter over sheath shall be as per Table no. 6 & 7 respectively		
Bedding	Two close helical lappings of PE or PP Tape with min. 5% overlap shall be provided under Armour		
D.S.T. Armour (For armoured cables only)	Two applications of G.S. Tape of 0.5mm/0.8 mm thickness as per Table 8 of specification conforming to IS 3975 each applied helically in the same direction with a gap in the first tape of $25 \pm 10\%$ of width of the tape and the second tape evenly covering the gap of first tape with an overlap of min. 20%		
Jacket (for Armoured Cables only)	Extruded polyethylene of grade 03C or H03C as per BS 6234 & thickness as per Table 9 of specification		

NOTE:-

☐ The given picture of the product may differ to its actual in construction/colour.



WE CONNECT FOR LIFE

Delton Cables Limited

Delton House, 4801, Bharat Ram Road 24, Darya Ganj, New Delhi-110002, INDIA
Tel.: ++91-11-23273905-07 Fax: +91-11-23280375, 23272178

Website: <http://www.deltoncables.com>

E-mail: dcl@deltoncables.com