



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO: ICWRWO0073911-1
DATE : 17-08-2009

SHEET 2 of 2

Sr. NO	Cl. No.	Tests	Requirement as per Specification	Obtained value	Remarks
1	IEC 60331 (Pt.-21) - 1999	Test under fire conditions – Circuit integrity (at 750°C for 90 minutes)	No fuse fails or circuit breaker is interrupted and the lamp is not extinguished during the test period	Withstood	Conforms

[Signature]

PREPARED BY



[Signature]
CHECKED BY

TE 0270095



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




TEST REPORT

SHEET 1 of 2

NAME & ADDRESS OF CUSTOMER		REPORT NO. :	ICWRWO0073911-2
M/s Delton Cables Ltd., 17/4, Mathura Road, Faridabad-121 002 (Haryana)		DATE :	17-08-2009
		CUSTOMER REF NO :	DF/QA/ACT/2009/69
		DATED :	25-07-2009
		DATE OF SAMPLE RECEIPT	DATES OF TESTING
		30-07-2009	10-08-09 to 12-08-09
SAMPLE DESCRIPTION		SAMPLE IDENTIFICATION	
2 Pair X 0.5 sq.mm copper/mica zero Halogen Insulated Aluminium Mylar tape screened and zero Halogen sheathed 300V peak grade Instrumentation cable.		Printing: DELTON CABLES LTD 2008 300V. 0.80 MM X 2 PAIR IEC -331.	
Sr. No.	TEST DETAILS	TEST SPECIFICATION	
1	Test under fire conditions – Circuit integrity	IEC 60331 (Pt.-21) – 1999	

REMARK: The sample conforms to the requirement for the above mention test.


NOTE: The LPG was used as a flame fuel.



PREPARED BY




CHECKED BY



APPROVED BY

- NOTE:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only the tests asked for by the customer have been carried out.



TE 0270057



Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.




EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO: ICWRWO0073911-2		SHEET 2 of 2			
DATE : 17-08-2009					
Sr. NO	Cl. No.	Tests	Requirement as per Specification	Obtained value	Remarks
1	IEC 60331 (Pt.-21) - 1999	Test under fire conditions – Circuit integrity (at 750°C for 90 minutes)	No fuse fails or circuit breaker is interrupted and the lamp is not extinguished during the test period	Withstood	Conforms
PREPARED BY 				CHECKED BY 	

TE 0270096